

**From:** [Paquette, Douglas E](#)  
**To:** [Howe, Robert F](#); [Brian Jankauskas \(brian.jankauskas@dec.ny.gov\)](#); [Rapiejko, Andrew \(Andrew.Rapiejko@suffolkcountyny.gov\)](#); [Hartzell, Sharon](#)  
**Cc:** [Dorsch, William R](#); [Remien, Jason](#); [Grenzen, Gerald \(BHSO\)](#)  
**Subject:** Private Well Summary - Correction  
**Date:** Wednesday, April 22, 2020 11:52:38 PM

---

Hi all,

The samples collected from three locations discussed below had **PFOA** concentrations >10ng/L, **not PFOS** as indicated earlier (corrections are highlighted in yellow).

Sorry for any confusion.

Doug

---

Below is a summary of the private well sampling program conducted to date.

- 70 properties/72 wells have been sampled
  - 12 of these are from the “new” list of 50
- All PFAS results are in:
  - All combined PFOA/PFOS concentrations were <70 ng/L HAL
  - **3 locations** had **PFOA** >10 ng/L proposed NYS DWS
    - The maximum **PFOA** concentration was 23 ng/L; this property is now connected to public water
    - The 3 properties are located close to two of the suspected source areas examined by the NYSDEC
  - **1 location** had individual PFOS and PFOA concentrations >10 ng/L proposed NYS DWS
    - PFOS was 19 ng/L and PFOA was 28 ng/L
    - There are no obvious PFAS sources upgradient of this property
- Most 1,4-dioxane results are in:
  - Of the reported 1,4-dioxane results, all are <1 ug/L proposed NYS DWS
    - Maximum concentration is 0.41 ug/L
  - Results for 15 wells are pending

The SCDHS informed us that due to the COVID-19 response, all private well sampling has been suspended. The TSA expired on March 31, 2020. It is likely that the County will request that the TSA be extended.